



LID TO BE NEENAH R-6661-LH ALUMINUM  
W/TYPE G LIFT HANDLES & RATCHETS &  
TYPE J (T HANDLES) LOCK OR APPROVED  
EQUAL. CENTER LID LENGTHWISE OVER  
DOMESTIC METER

MASTIC  
WATER TIGHT SEAL  
UR227 NS JOINT  
SEALANT OR EQUAL

6" FLOOR DRAIN  
JOSAM TYPE 32226 OR  
EQUAL TO STORM  
SEWER (CENTER DRAIN  
UNDER MANHOLE LID)

TO DOMESTIC SERVICE  
TYPE K COPPER TO  
3' OUTSIDE OF PIT

- ① DETECTOR CHECK VALVE ASSEMBLY  
SEE CCSD STD. DWG. W3.1
- ② TAPPING SADDLE & CORPORATION STOP
- ③ DOMESTIC METER - SEE CCSD STD. DWGS. W3.2 & W3.3
- ④ FLANGED CONCENTRIC REDUCER
- ⑤ FLANGED INDICATOR GATE VALVE W/ HANDWHEEL OR POST  
INDICATOR VALVE, AS REQUIRED BY FIRE DEPARTMENT  
ELECTRONIC SUPERVISION OF VALVE AS REQUIRED
- ⑥ FIRE DEPARTMENT CONNECTION, IF REQUIRED BY FIRE DEPARTMENT

**NOTE:**

SEE CCSD STANDARD DWGS W4.5  
& W4.6 FOR WATER SYSTEM  
CHAMBER DETAILS

NO SCALE



CLERMONT COUNTY  
SEWER DISTRICT

APPROVED \_\_\_\_\_  
DATE \_\_\_\_\_

DUAL SERVICE  
BRANCH SETTING-  
DOMESTIC METERS  
(2" & SMALLER)

DRAWING NO.

W4.2